# AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

| | 1. CONTRACT ID CODE | PAGE OF PAGES | |
|---|---|---|---|
| | J | 1 | 2 |

| 2. AMENDMENT/MODIFICATION NO. | 3. EFFECTIVE DATE | 4. REQUISITION/PURCHASE REQ. NO. | 5. PROJECT NO.(If applicable) |
|---|---|---|---|
| 0006 | 05-Sep-2002 | W16ROE-2168-2014 | |

| 6. ISSUED BY | CODE | DACA51 | 7. ADMINISTERED BY (If other than item 6) | CODE | |
|---|---|---|---|---|---|

USA ENGINEER DISTRICT, NEW YORK
ATTN: CENAN-CT ROOM 1843
26 FEDERAL PLAZA (DACA51)
NEW YORK NY 10278-0090

**See Item 6**

| 8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code) | | |
|---|---|---|
| | X | 9A. AMENDMENT OF SOLICITATION NO. DACA51-02-B-0019 |
| | X | 9B. DATED (SEE ITEM 11) 02-Aug-2002 |
| | | 10A. MOD. OF CONTRACT/ORDER NO. |
| | | 10B. DATED (SEE ITEM 13) |
| CODE      FACILITY CODE | | |

## 11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

[X] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer [X] is extended, [ ] is not extended.

Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods:
(a) By completing Items 8 and 15, and returning ___1___ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;
or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

## 13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.

B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).

C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:

D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor [ ] is not, [ ] is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)
The purpose of this amendment is as follows:
1) Provide Bidders with answers to questions/inquires received by the Government
2) Postpone the Bid Opening from 2:00 PM on 6 September 2002 to 11:00 AM on 12 September 2002
3) Inform Bidders of a forthcoming amendment containing new wage determinations. The issuance of the new wage determination will not extend the bid opening beyond 12 September 2002.

All other terms and conditions remain the same.

NOTE: Bidders must acknowledge receipt of this amendment by the date specified in the solicitation (or as amended) by one of the following methods: In the space provided on the SF 1442, by seperate letter, or by telegram, or by signing the block 15 below. FAILURE TO ACKNOWLEDGE AMENDMENTS BY THE DATE AND TIME SPECIFIED MAY RESULT IN REJECTION OF YOUR BID IN ACCORDANCE WITH THE LATE BID, LATE MODIFICATIONS OF BIDS OR LATE WITHDRAWAL OF BIDS (FAR 14.304)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

| 15A. NAME AND TITLE OF SIGNER (Type or print) | 16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) | |
|---|---|---|
| | TEL:               EMAIL: | |
| 15B. CONTRACTOR/OFFEROR | 16B. UNITED STATES OF AMERICA BY | 16C. DATE SIGNED |
| (Signature of person authorized to sign) | (Signature of Contracting Officer) | 05-Sep-2002 |

| 15C. DATE SIGNED | | |

EXCEPTION TO SF 30
APPROVED BY OIRM 11-84

30-105-04

STANDARD FORM 30 (Rev. 10-83)
Prescribed by GSA
FAR (48 CFR) 53.243

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

**SUMMARY OF CHANGES**

SECTION  SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

AMENDMENT 6
**BIDDER'S QUESTIONS AND GOVERNMENT REPLY**

Bidder's questions appear below and are numbered.  The Government reply to questions follow each question. *(Questions that may be of general interest of all bidders/Government and that are not readily answered by the proceeding changes may appear below.  These questions may have been paraphrased or altered to represent several questions regarding the same subject and/or clarify and simplify the question(s).  Questions and answers are issued to the Offerors/Bidders for information only.)*

1. Is my understanding correct that the only acoustical ceiling work is for the sprinkler work required in the existing office space?

    Yes. The ceiling work is confined to the two-story office/shops area within the Hangar. Amendment 0003 clarified Keyed note 02220.24 sheet AD101 to read "REMOVE EXISTING CEILING TO INSTALL NEW FIRE SPRINKLER PIPING." Sheet AE101 Keyed note 02220.24 was removed from the Keyed Notes and was replaced with Keyed note 01000.14 (four locations) on the Ground Floor Plan. Keyed note 01000.14 was clarified to read "INSTALL NEW SUSPENDED CEILING TO MATCH ORIGINAL CEILING TYPE IN AREAS WHERE CEILING WAS REMOVED FOR FIRE SPRINKLER INSTALLATION."

2. Is the new water line ductile iron or polyethylene?

    See Detail 4,5,6,7 and 8 on sheet CU501. The majority of the pipe is HDPE with DIP at the entries to buildings 1823 and1837 and fire hydrant/valve assembly

3. There is no specification section for fencing. What is the location of the fence?

    Specifications for the Construction fencing are in section 00800 paragraph 1.aa. . Amendment 0003 adds a General Note to sheet CS102 covering the approximate limits of the fencing.

4. What is the extent of the work for landscaping/sod? No mention on drawing(s). Is this Option 2 or Option 3?

    Existing turf areas disturbed during construction will be restored with sod per specification 02922A. This requirement applies to both Option 2 and Option 3.

5. Please provide a detail for the asphalt replacement.

    No asphalt pavement is used for replacement. Pavement will be patched using concrete. See detail 2 on sheet CU501.

6. There are no specifications for Weather-stripping, detail 4/SF501.

    Weather stripping is covered in specification 08342 paragraph 2.1.9 and related sub-paragraphs.


(End of Summary of Changes)